



**QUALITY CONTROL &
TECHNICAL DATA SHEET**
**0104- Natural & Ceramized Glass
Plaster**

COMPANY	Bekoteks Yapı Sanayi ve Dış Ticaret Ltd. Şti.
MATERIAL	Natural & Ceramized Glass Plaster
QUALITY CERTIFICATE	TS EN İSO 9001: 2008
DATE	10.05.2018
CERTIFICATED NUMBER	3101019
PRODUCTION STANDARD	----

Viscosity	Viscous
Density	1,78±0,02 g/cm ³
pH	8-9,5
Appearance	Milky white after dry becomes transparent (of resin), Various colors as on catalogue (of product)
Flash Point	Water Based
Hard Dose	72,60
Dry	4-6 hour
(P.V.A)Resin	20%
Water	5 %

	VOC, g/L	
	limit	result
According to the test results from university (M.E.T.U.)		
Middle East Technical University	≤ 30	7

TESTED BY
SIGNATURE/ DATE

APPROVED BY
SIGNATURE/ DATE